



CALIFORNIA STATE FIRE MARSHAL LISTED, COMBINATION FIRE AND BURGLAR FIRE ALARM CONTROL PANELS

DATE: February 17, 2010

INFORMATION BULLETIN: E-09-008

APPROVED BY: *MSB*

Policy:

2007 California Fire Code, Section 907.1.4

A fire alarm system shall not be used for any purpose other than fire warning unless approved by the enforcing agency.

Combination fire and burglar systems are not approved for use within the City of Riverside based on the following:

Battery back up to be dedicated to fire equipment.

Unlicensed personnel working on fire alarm control panel.

Burglar devices (quantity, type, calculations) are hard to regulate.

Exception:

R-3 Occupancies may utilize California State Fire Marshal listed combination fire and burglar control panels.